Certificate of Conformity

Certificate Number: CN-PVES-250133

On the basis of the tests undertaken, the sample<s> of the below product have been found to comply with the requirements of the referenced specification<s>/standard<s> at the time the tests were carried out. It does not imply that Intertek has performed any surveillance or control of the manufacture(s). The manufacturer(s) shall ensure that the manufacturing process assures compliance of the production units with the examined products mentioned in this certificate.

Applicant:	Huizhou Epever Technology Co.,Ltd. No. 6 Laowu Road, Start-up Area of China-Korea (Huizhou) Industrial Park, Zhongkai District, Huizhou City, Guangdong Province, China
Product: **Ratings & Principle Characteristics:**	On-grid PV Inverter See appendix of Certificate of Conformity
Model:	SPS3KTL, SPS3.6KTL, SPS4KTL, SPS4.6KTL, SPS5KTL, SPS6KTL
Brand Name<s>:	EPEVER
Product Complies with:	IEC 61727:2004 Photovoltaic (PV) systems – Characteristics of the utility interface IEC 62116:2014 Test procedure of islanding prevention measures for utility-interconnected photovoltaic inverters
Certificate Issuing Office Name & Address:	Intertek Testing Services Ltd. Shanghai West Area, 2nd Floor, No. 707, Zhangyang Road China (Shanghai) Pilot Free Trade Zone, Shanghai, P. R. China Accredited by ACCREDIA in accordance with ISO/IEC 17065:2012
Test Report No.<s>:	241115018GZU-001, 17 Mar 2025 241115018GZU-002, 17 Mar 2025

Additional information in Appendix.

Signature

Certification Manager: Grady Ye
Date: 31 March 2025

ACCREDIA
L'ENTE ITALIANO DI ACCREDITAMENTO

PRD N° 306B

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250133

Ratings & Principle Characteristics:

Models	SPS3KTL	SPS3.6KTL	SPS4KTL	SPS4.6KTL	SPS5KTL	SPS6KTL
Nominal Power Output to Utility Grid (W)	3000	3600	4000	4600	5000	6000
PV String Input Data						
Max. Input Power (W)	4500	5400	6000	7500	7500	9000
Max. Input Voltage (V)	600					
MPPT Operating Voltage Range (V)	70-550					
Start-up Voltage (V)	90					
Nominal Input Voltage (V)	360					
Max. Input Current per MPPT (A)	16		16*2			
Max. Short Circuit Current per MPPT (A)	20		20*2			
Number of MPPTs/Number of Strings per MPPT	1		2			
AC Output Data (On-grid)						

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.

APPENDIX: Certificate of Conformity

This is an Appendix to Certificate of Conformity Number: CN-PVES-250133

Max. Apparent Power Output to Utility Grid (W)	3300	3960	4400	4600	5500	6000
Nominal Output Voltage (V)	230					
Nominal AC Grid Frequency (Hz)	50/60					
Max. AC Current Output to Utility Grid (A)	14.4	17.3	19.1	22	24	28.6
Power Factor	0.8 lagging to 0.8 leading					
Software version	V1.0					

This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.